



Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: June 9, 2016 (Revised)

Client: Allegro School
Address: 125 Ridgedale Avenue
Cedar Knolls, NJ 07927

Project: Allegro School

Sample description: Drinking Water / 1st Draw / DWS3083-1
Sample location: 1st Floor O.T. Room
Sampled by: Client
Sample date: 06/02/16
Time: 06:06
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.73 ug/L	15 ug/L	06/03/16	14:19	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-2
Sample location: 1st Floor Break Room (Staff Caf.)
Sampled by: Client
Sample date: 06/02/16
Time: 06:08
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	7.93 ug/L	15 ug/L	06/03/16	14:25	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-3
Sample location: 1st Floor A.R.S.
Sampled by: Client
Sample date: 06/02/16
Time: 06:03
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	14:31	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-4
 Sample location: 2nd Floor Kitchen
 Sampled by: Client
 Sample date: 06/02/16
 Time: 06:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	14:36	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-5
 Sample location: 2nd Floor Boys' Room Sink 1
 Sampled by: Client
 Sample date: 06/02/16
 Time: 06:12
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	14:53	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-6
 Sample location: 2nd Floor Nurse's Office
 Sampled by: Client
 Sample date: 06/02/16
 Time: 06:10
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	14:59	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-7
 Sample location: 3rd Floor A.D.L.
 Sampled by: Client
 Sample date: 06/02/16
 Time: 06:16
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.30 ug/L	15 ug/L	06/03/16	15:04	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3083-8
 Sample location: Field Blank
 Sampled by: Client
 Sample date: 06/02/16
 Time: 06:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	06/03/16	15:10	2 ug/L

ug/L = micrograms per liter


All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

June 10, 2016
Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: <u>Allegro School</u>	report to:	Agra Environmental Services
Address: <u>125 Ridgedale Avenue</u> <u>Cedar Knolls, NJ 07927</u>	<u>David Bilenker, Principal</u>	90½ West Blackwell Street Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: <u>Tom: 973-800-2009</u>		Fax: (973) 989-0156
Work: <u>(973) 285-0725</u>		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: <u>Allegro School</u>	Collection	PWSID# <u>None</u>					for laboratory use only	Field Analysis	
<u>DWS3883</u>	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
1st Fl. - O.T. Room	-1	<u>6/2/16</u>	<u>0606</u>	X		D	1	HN03	1st Draw Pb <u>3.73 µg/L</u> <u>6/3</u> <u>1419</u> <u>BM</u>
1st Fl. - Break Room (Staff Caf.)	-2		<u>0608</u>	X		D	1	HN03	1st Draw Pb <u>7.93 µg/L</u> <u>1425</u>
1st Fl. - A.R.S.	-3		<u>0603</u>	X		D	1	HN03	1st Draw Pb <u><2 µg/L</u> <u>1431</u>
2nd Fl. - Kitchen	-4		<u>0614</u>	X		D	1	HN03	1st Draw Pb <u><2 µg/L</u> <u>1436</u>
2nd Fl. - Boy's Room <u>Sink 1</u>	-5		<u>0612</u>	X		D	1	HN03	1st Draw Pb <u><2 µg/L</u> <u>1453</u>
2nd Fl. - Nurse's Office	-6		<u>0610</u>	X		D	1	HN03	1st Draw Pb <u><2 µg/L</u> <u>1459</u>
3rd Fl. - A.D.L.	-7		<u>0616</u>	X		D	1	HN03	1st Draw Pb <u>2.30 µg/L</u> <u>1504</u>
<u>Field Blank</u>	<u>-8</u>		<u>0600</u>	X			1	<u>NA</u>	1st Draw Pb <u>Field Blank</u> <u><2 µg/L</u> <u>6/3 1510</u> <u>BM</u>

Sampled By (name/company): <u>D. Diaz / Agra</u>	State Forms Needed (circle one): Yes or No	indicate laboratory location where analysis requested was performed
	<input type="radio"/> Yes <input type="radio"/> No	
	<input type="checkbox"/> NJDEP Laboratory Certification (Dover, NJ) #14013	
	<input type="checkbox"/> NJDEP Laboratory Certification (Marlboro, NJ) #13033	

Reporting Requirements (Check Box):	<input type="checkbox"/> Standard	<input type="checkbox"/> NJ Reduced	<input type="checkbox"/> Other (Specify)	Cooler Temperature Upon Receipt at lab: <u>6.5°C</u>
-------------------------------------	-----------------------------------	-------------------------------------	--	---

Sample Custody Exchanges (Please use full legal signature)						Scanned <u>JUN 10 2016</u> <u>250 mL Sampler</u>
Relinquished By: <u>David Diaz</u>	Date: <u>6/2/16</u>	Time: <u>0645</u>	Received By: <u>S. Meyer</u>	Date: <u>6/2/16</u>	Time: <u>0833</u>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Date Faxed _____						Invoice Number _____
Is sample known to be hazardous? (circle one) Yes or No						